

Docket Item #5
BAR CASE# 2005-0043

BAR Meeting
April 6, 2005

ISSUE: Permit to Demolish
APPLICANT: Ken & Olena Harvey
LOCATION: 221 Princess Street
ZONE: RM/Residential

STAFF RECOMMENDATION:

Staff recommends approval of the application as submitted.

Note: This docket item requires a roll call vote.

I. ISSUE:

The applicant is requesting approval of a Permit to Demolish approximately 46 square feet of the existing roof. The demolition is required for the installation of four skylights.

The rear slope of the roof at 221 Princess Street is minimally visible from North Fairfax Street.

II. HISTORY:

The three story brick residential rowhouse at 221 Princess Street was constructed in 1977 as part of the Princess Street Townhouses development project in a Federal revival design style.

III. ANALYSIS:

In considering a Permit to Demolish/Capsulate, the Board must consider the following criteria set forth in the Zoning Ordinance, §10-105(B):

- (1) Is the building or structure of such architectural or historical interest that its moving, removing, capsulating or razing would be to the detriment of the public interest?
- (2) Is the building or structure of such interest that it could be made into a historic house?
- (3) Is the building or structure of such old and unusual or uncommon design, texture and material that it could not be reproduced or be reproduced only with great difficulty?
- (4) Would retention of the building or structure help preserve the memorial character of the George Washington Memorial Parkway?
- (5) Would retention of the building or structure help preserve and protect an historic place or area of historic interest in the city?
- (6) Would retention of the building or structure promote the general welfare by maintaining and increasing real estate values, generating business, creating new positions, attracting tourists, students, writers, historians, artists and artisans, attracting new residents, encouraging study and interest in American history, stimulating interest and study in architecture and design, educating citizens in American culture and heritage, and making the city a more attractive and desirable place in which to live?

Staff believes that none of the criteria are met. The proposed demolition is limited to areas of the late twentieth century roof.

IV. STAFF RECOMMENDATION:

Staff recommends approval of the application as submitted.

CITY DEPARTMENT COMMENTS

Legend: C - code requirement R - recommendation S - suggestion F- finding

Code Enforcement:

- F-1 The submitted plans do not provide a sufficient information to provide comprehensive code comments. Therefore, additional requirements may be required of the applicant at the time of permit application.

- F-2 The proposed finished attic space may exceed the height and area requirements of the USBC and require addition fire protection measures including but not limited to a fire suppression system and emergency escape windows.

- C-1 All exterior walls within 5 feet from an interior property line shall have a fire resistance rating of 1 hour, from both sides, with no openings permitted within the wall. As alternative, a 2 hour fire wall may be provided. This condition is also applicable to skylights within setback distance.

- C-2 New construction must comply with the current edition of the Uniform Statewide Building Code (USBC).

- C-3 Alterations to the existing structure must comply with the current edition of the Uniform Statewide Building Code (USBC).

- C-4 Construction permits are required for this project. Plans shall accompany the permit application that fully detail the construction as well as layouts and schematics of the mechanical, electrical, and plumbing systems.

Office of Historic Alexandria:

No comment