

Docket Item #19
BAR CASE #2005-0135

BAR Meeting
July 6, 2005

ISSUE: Demolition for a new dormer
APPLICANT: Mr. And Mrs. F. Manning by Walter Borek
LOCATION: 213 Cameron Street
ZONE: CD/Commercial

STAFF RECOMMENDATION:

Staff recommends approval of the application as submitted.

Note: This docket item requires a roll call vote.

I. ISSUE:

The applicant is requesting approval of a Permit to Demolish portions of the roof of the house at 213 Cameron Street in order to construct a new dormer. The area of the roof to be demolished is northwest section of the roof and entails an area of approximately 120 square feet, 10' x 12'. The area of the roof proposed to be demolished as well as the new dormer are not visible from the public right-of-way. However, all proposed demolition in the historic district over 25 square feet is reviewed by the Board regardless of visibility from the public right-of-way.

II. HISTORY:

The two story brick house at 213 Cameron Street was built in 1981.

III. ANALYSIS:

In considering a Permit to Demolish, the Board must consider the following criteria set forth in the Zoning Ordinance, §10-105(B):

- (1) Is the building or structure of such architectural or historical interest that its moving, removing, capsulating or razing would be to the detriment of the public interest?
- (2) Is the building or structure of such interest that it could be made into a historic house?
- (3) Is the building or structure of such old and unusual or uncommon design, texture and material that it could not be reproduced or be reproduced only with great difficulty?
- (4) Would retention of the building or structure help preserve the memorial character of the George Washington Memorial Parkway?
- (5) Would retention of the building or structure help preserve and protect an historic place or area of historic interest in the city?
- (6) Would retention of the building or structure promote the general welfare by maintaining and increasing real estate values, generating business, creating new positions, attracting tourists, students, writers, historians, artists and artisans, attracting new residents, encouraging study and interest in American history, stimulating interest and study in architecture and design, educating citizens in American culture and heritage, and making the city a more attractive and desirable place in which to live?

Since this is a late 20th century house, it is the opinion of Staff that none of the criteria are met and that the Permit to Demolish should be approved.

IV. STAFF RECOMMENDATION:

Staff recommends approval of the application as submitted.

CITY DEPARTMENT COMMENTS

Legend: C - code requirement R - recommendation S - suggestion F - finding

Code Enforcement:

- C-1 All exterior walls within 5 feet from an interior property line shall have a fire resistance rating of 1 hour, from both sides of the wall. As alternative, a 2 hour fire wall may be provided. This condition is also applicable to skylights within setback distance. Openings in exterior walls between 3 and 5 feet shall not exceed 25% of the area of the entire wall surface (This shall include bay windows). Openings shall not be permitted in exterior walls within 3 feet of an interior lot line.
- C-2 New construction must comply with the current edition of the Uniform Statewide Building Code (USBC).
- C-3 Alterations to the existing structure must comply with the current edition of the Uniform Statewide Building Code (USBC).
- C-4 Construction permits are required for this project. Plans shall accompany the permit application that fully detail the construction as well as layouts and schematics of the mechanical, electrical, and plumbing systems.

Historic Alexandria:

No comment.