

Docket Item #12
BAR CASE #2005-0187

BAR Meeting
December 7, 2005

ISSUE: Demolition and capsulation

APPLICANT: J. & Katy Kenny

LOCATION: 114 N. Payne Street

ZONE: CD/Commercial

STAFF RECOMMENDATION:

Staff recommends approval of the application as submitted.

NOTE: This docket item requires a roll call vote.

I. ISSUE:

The applicant is requesting approval of a Permit to Demolish and encapsulation of the west elevation and the south elevation in order to construct a new addition and add new windows and doors.

II. HISTORY:

The front part of the house facing the street was constructed in 1875 by a local carpenter who resided there. The house originally had a steeply pitched cross gable typical of “Gothic” cottages of the mid to late Victorian period of the 19th century. It may have had a full ensemble of “gingerbread” trim as was typical of these modest cottages but no images are known to exist showing this condition. The cross gable was removed, possibly in the 1980’s, and the existing two story addition was created probably in the mid-20th c. The fundamental character of the house has been compromised over time by these generally unsympathetic alterations.

III. ANALYSIS:

In considering a Permit to Demolish/Capsulate, the Board must consider the following criteria set forth in the Zoning Ordinance, §10-105(B):

- (1) Is the building or structure of such architectural or historical interest that its moving, removing, capsulating or razing would be to the detriment of the public interest?
- (2) Is the building or structure of such interest that it could be made into a historic house?
- (3) Is the building or structure of such old and unusual or uncommon design, texture and material that it could not be reproduced or be reproduced only with great difficulty?
- (4) Would retention of the building or structure help preserve the memorial character of the George Washington Memorial Parkway?
- (5) Would retention of the building or structure help preserve and protect an historic place or area of historic interest in the city?
- (6) Would retention of the building or structure promote the general welfare by maintaining and increasing real estate values, generating business, creating new positions, attracting tourists, students, writers, historians, artists and artisans, attracting new residents, encouraging study and interest in American history, stimulating interest and study in architecture and design, educating citizens in American culture and heritage, and making the city a more attractive and desirable place in which to live?

In the opinion of Staff, none of the above criteria are met. The proposed areas to be demolished or encapsulated are to the rear of the property and impact only the existing two story addition that was created probably in the mid-20th c.

IV. STAFF RECOMMENDATION:

Therefore, Staff recommends approval of the application as submitted.

CITY DEPARTMENT COMMENTS

Legend: C - code requirement R - recommendation S - suggestion F- finding

Code Enforcement:

- C-1 All exterior walls within 5 feet from an interior property line shall have a fire resistance rating of 1 hour, from both sides of the wall. As alternative, a 2 hour fire wall may be provided. This condition is also applicable to skylights within setback distance. Openings in exterior walls between 3 and 5 feet shall not exceed 25% of the area of the entire wall surface (This shall include bay windows). Openings shall not be permitted in exterior walls within 3 feet of an interior lot line.

- C-2 Prior to the issuance of a demolition permit or land disturbance permit, a rodent abatement plan shall be submitted to Code Enforcement that will outline the steps that will taken to prevent the spread of rodents from the construction site to the surrounding community and sewers.

- C-3 Roof drainage systems must be installed so as neither to impact upon, nor cause erosion/damage to adjacent property.

- C-4 A soils report must be submitted with the building permit application.

- C-5 New construction must comply with the current edition of the Uniform Statewide Building Code (USBC).

- C-6 Alterations to the existing structure must comply with the current edition of the Uniform Statewide Building Code (USBC).

- C-7 Construction permits are required for this project. Plans shall accompany the permit application that fully detail the construction as well as layouts and schematics of the mechanical, electrical, and plumbing systems.

- C-8 Permission from adjacent property owners is required if access to the adjacent properties is required to complete the proposed construction. Otherwise, a plan shall be submitted to demonstrate the construction techniques utilized to keep construction solely on the referenced property.

- C-9 A wall location plat prepared by a land surveyor is required to be submitted to this office prior to requesting any framing inspection.

- C-10 Basement windows shall meet the requirements for Emergency Escape per the USBC.

Historic Alexandria:

“No comment.”

Alexandria Archaeology:

- F-1 The G.M. Hopkins Insurance map shows that a house was present on this property by 1877. Therefore, there is the potential for archaeological resources to be present that could provide insight into residential life in early Alexandria.

- R-1 Call Alexandria Archaeology immediately (703-838-4399) if any buried structural remains (wall foundations, wells, privies, cisterns, etc.) or concentrations of artifacts are discovered during development. Work must cease in the area of the discovery until a City archaeologist comes to the site and records the finds.

- R-3 The above statement in R-1 must appear in the General Notes of all site plans so that on-site contractors are aware of the requirement.