

Docket Item # 7
BAR CASE # 2006-0291

BAR Meeting
February 21, 2007

ISSUE: After-the-fact shed
APPLICANT: Christopher Campagna
LOCATION: 816 Duke Street
ZONE: RM/Residential

STAFF RECOMMENDATION: Staff recommends approval of the application with the condition that the siding on the east side be replaced with painted wood German siding to match that on the other three elevations.

(Insert sketch here)

I. ISSUE:

The applicant is requesting after-the-fact approval of a frame shed located in the back yard of the house at 816 Duke Street. According to the applicant, the shed will function as a combination play house and storage shed. Staff became aware of the shed through a citizen complaint filed on November 16, 2006 and subsequently notified the applicant of the need to apply for BAR approval. The applicant has been working with Staff to provide the necessary information to demonstrate compliance with the zoning requirements and to allow BAR review.

The shed measures 8' by 12' and is located against the east side property line, and 8.33' from the rear property line. It has a shed roof sloping down toward the east. At its highest point, the shed is 9' and 8' at its lowest point. The shed will be clad in 6" wide German wood siding painted to match the house. The roof will be clad in painted standing seam metal. The trim, including corner boards and fascia, will be wood painted white. On the north elevation, which faces the house and will not be visible to the public, there will be a wood, Dutch door with two panels below and four lights above and a true divided light wood casement window with four lights. The long west elevation will have a six panel painted wood door on the north end and a true divided light wood casement window with four lights. The south elevation will have no openings. The long east elevation, which is not shown in the plans and which abuts the existing carport at 814 Duke Street, is already sided in unpainted T-111 has no openings.

The shed is visible from the public alley at the rear of the house above the 6' rear fence. (Please note that the rear fence is a flat board fence, not a stockade fence as shown in the notes on the plan.)

II. HISTORY:

The two story, Victorian Second Empire style frame residence at 816 Duke Street was constructed in 1870 according to the tax records and is noted on the 1877 Hopkins map.

The Board approved an addition and alterations to this property including replacement fencing on 11/18/1992 (BAR Case #92-209). On 3/17/1993, the Board approved revisions to the plans for the addition (BAR Case #93-46).

III. ANALYSIS:

The existing shed meets the requirements of the zoning ordinance, including open space and side and rear yard requirements for the RM zone.

Staff believes the shed, as it is proposed to be finished, will comply with the *Design Guidelines for Accessory Structures* (Pages 1-4). The simple design and traditional form of the shed is appropriate for the Vernacular Victorian main structure. The proposed exterior materials, including German siding and standing seam metal will complement the main building.

Staff's only concern is with the east elevation which is already sided in unpainted T-111 siding. T-111 is a 20th century product and not of the same quality or traditional appearance as the German lap wood siding proposed for the other elevations. In addition, as noted in the *Design Guidelines*, "unpainted siding is generally not appropriate in an urban setting" (Siding – Page 2).

IV. STAFF RECOMMENDATION:

Therefore, Staff recommends approval of the application with the condition that the siding on the east side be replaced with painted wood German siding to match that on the other three elevations.

CITY DEPARTMENT COMMENTS

Legend: C - code requirement R - recommendation S - suggestion F- finding

Code Enforcement:

“No comments.”

Historic Alexandria:

No comments received.