

Docket Item # 13
BAR CASE # 2007-0095

BAR Meeting
June 6, 2007

ISSUE: Alterations
APPLICANT: James C. Heffner, III
LOCATION: 604 Montgomery Street
ZONE: CDX/Commercial

STAFF RECOMMENDATION: Staff recommends deferral for restudy.

(Insert sketch here)

I. ISSUE:

The applicant is requesting approval of a certificate of appropriateness for alterations to the front of the building located at 604 Montgomery Street. The alterations consist of the following:

- 1) Existing wood windows, doors, and transoms on the first floor to be removed and new metal storefront door, transoms, and windows to be installed.
- 2) Replace existing window in the second floor bay with new metal storefront window.
- 3) Replace existing trim at roof of second floor bay window.
- 4) Install new exterior lights at the existing junction boxes.
- 5) New business sign on storefront door.

The proposed storefront system is manufactured by Kawnee and will have a dark bronze metal finish. The applicant provided manufacturer information on the storefront system proposed for the replacement windows and door.

The proposed window sign will be on the front door and read "Heffner Architects, P.C." The sign will cover 1'8 1/4" x 11 1/4" of glass on the upper section of the door.

The four new aluminum light fixtures are manufactured by Artemide and will be wall mounted at the four existing junction boxes. The manufacturer information shows the model in white or black; it is unclear which color the applicant is requesting.

II. HISTORY:

According to real estate records, 604 Montgomery Street was constructed in 1946.

Staff did not locate any prior reviews or approvals by the Board for this property at 604 Montgomery Street.

III. ANALYSIS:

Proposed window sign, door, window and lighting alterations comply with zoning ordinance requirements.

604 Montgomery Street is a two story brick building with a hipped roof, clad in slate, and a cupola on the flat of the roof, with a wood railing surround. In staff's opinion, 604 Montgomery Street is a good example of a commercial project constructed to reflect the colonial architectural heritage of the Old and Historic Alexandria District. The use of brick exterior, brick arches with cast key stones, a slate roof, and wood trim is in keeping with the philosophy of the Design Guidelines that encourages the use of traditional materials in construction within the Historic District.

As discussed in the History section, the building was constructed in 1946, the year the Old and Historic Alexandria District was established. Staff could not locate any records to demonstrate if the building has been altered since its construction. Staff did visit the building and observed that the existing wood window and door trim was in a deteriorating state. However, Staff is concerned about replacing the wood doors, windows, and trim with metal storefront systems. In Staff's opinion, the introduction of the storefront system changes the appearance of the building

and removes character-defining features. Staff is also concerned about the proposed new exterior lights. Staff recommends that the existing wood windows and doors be maintained and repaired or replaced with inkind materials and that an alternate lighting fixture be explored. Staff does support the new signage.

IV. STAFF RECOMMENDATION:
Staff recommends deferral for restudy.

CITY DEPARTMENT COMMENTS

Legend: C - code requirement R - recommendation S - suggestion F- finding

Code Enforcement:

- C-1 The proposed use is a change in use group classification; a New Certificate of Occupancy is required (USBC 116.1).
- C-2 Alterations to the existing structure must comply with the current edition of the Uniform Statewide Building Code (USBC).
- C-3 Additions and alterations to the existing structure and/or installation and/or altering of equipment there requires a building permit (USBC 108.1). Five sets of plans, bearing the signature and seal of a design professional registered in the Commonwealth of Virginia must accompany the written application (USBC 109.1).
- C-4 Construction permits are required for this project. Plans shall accompany the permit application that fully detail the construction as well as layouts and schematics of the mechanical, electrical, and plumbing systems.

Historic Alexandria:

No comments were received.