

Docket Item # 2
BAR CASE# 2005-00245

BAR Meeting
November 7, 2005

ISSUE: Demolition

APPLICANT: Public Opinion Strategies

LOCATION: 214 North Fayette Street

ZONE: CRMU-M

****EXPIRATION OF APPROVALS NOTE:** In accordance with Sections 10-106(B) and 10-206(B) of the Zoning Ordinance, any official Board of Architectural Review approval will expire 12 months from the date of issuance if the work is not commenced and diligently and substantially pursued by the end of that 12-month period.

****BUILDING PERMIT NOTE:** Most projects approved by the Board of Architectural Review require the issuance of one or more construction permits by the Code Enforcement Bureau (including signs). The applicant is responsible for obtaining all necessary construction permits after receiving Board of Architectural Review approval. Contact Code Enforcement, Room 4200, City Hall, 703-838-4360 for further information.

STAFF RECOMMENDATION:

Staff recommends approval of the application as submitted.

NOTE: This docket item requires a roll call vote.

I. ISSUE:

The applicant is requesting approval of a Permit to Demolish portions of the commercial structure at 214 North Fayette Street, to convert the building from a bakery/restaurant use to an office use. The Demolition would include removal of existing brick to create new window openings on the east elevation, removal of existing windows and doors to be infilled with brick, and removal of metal awnings.

II. HISTORY:

The one story brick commercial/industrial building at 214 North Fayette Street was constructed in 1977 for a brick mason contractors office.

In 1997, the BAR approved requests for a Permit to Demolish and a Certificate of Appropriateness for Alterations and Additions, when the building was converted to a bakery use. The addition and alterations included an addition consisting of a semi-circular storefront entrance with a standing seam metal roof and new and replacement windows; standing seam metal awnings over most windows; individual letter signs; and, gooseneck lights to illuminate the signs.

III. ANALYSIS:

In considering a Permit to Demolish/Capsulate, the Board must consider the following criteria set forth in the Zoning Ordinance, Sec. 10-105(B):

- (1) Is the building or structure of such architectural or historical interest that its moving, removing, capsulating or razing would be to the detriment of the public interest?
- (2) Is the building or structure of such interest that it could be made into a historic house?
- (3) Is the building or structure of such old and unusual or uncommon design, texture, and material that it could not be reproduced or be reproduced only with great difficulty?
- (4) Would retention of the building or structure help preserve the memorial character of the George Washington Memorial Parkway?
- (5) Would retention of the building or structure help preserve and protect an historic place or area of historic interest in the city?
- (6) Would retention of the building or structure promote the general welfare by maintaining and increasing real estate values, generating business, creating new positions, attracting tourists, students, writers, historians, artists and artisans, attracting new residents, encouraging study and interest in American history, stimulating interest and study in architecture and design, educating citizens in American culture and heritage, and making the city a more attractive and desirable place in which to live?

Staff believes that none of the criteria are met and that the Permit to Demolish should be granted.

IV. STAFF RECOMMENDATION:

Staff recommends approval of the application as submitted.

CITY DEPARTMENT COMMENTS

Legend: C - code requirement R - recommendation S - suggestion F- finding

Code Enforcement:

- C-1 Roof drainage systems must be installed so as neither to impact upon, nor cause erosion/damage to adjacent property.
- C-2 New construction must comply with the current edition of the Uniform Statewide Building Code (USBC).
- C-3 Alterations to the existing structure must comply with the current edition of the Uniform Statewide Building Code (USBC).
- C-4 Construction permits are required for this project. Plans shall accompany the permit application that fully detail the construction as well as layouts and schematics of the mechanical, electrical, and plumbing systems.
- C-5 Canopies must comply with USBC 3202 for support and clearance from the sidewalk, and the applicable sections of USBC's Chapter 11. Structural designs of fabric covered canopies must comply with USBC 3105.3. The horizontal portions of the framework must not be less than 8 feet nor more than 12 feet above the sidewalk and the clearance between the covering or valance and the sidewalk must not be less than 7 feet.

Historic Alexandria:

"No comment."